

FINIVLAM[®]

maakt textiel brandvertragend

	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Sample 6
burned cm	0	0	0	0	0	0
burned parts fall down	0	0	0	0	0	0
afterglowing seconds	0	0	0	0	0	0
melting cm	1,5	1,2	1	1,3	0,5	0,8
result	ok	ok	ok	ok	ok	ok
Name: All Technical Trade Centre BV						
Adress: Hoevelakensingel 26						
Zippcode: 3077 SR						
City: Rotterdam						
Material tested: metallic						
Material name: metallic						
Material thickness:						
Weight sq meter: 34 gr./sq meter						
Testname: DIN 4102 B1						
Testnumber: 18709b						
Date: 8-5-2018						



[Handwritten signature]